



NOTES

1. Soakaways only to be used in permeable soil.
2. Where specified the outlet pipe invert should be half its diameter below the inlet pipe invert.
3. For chambers up to 2 metres deep step irons Top iron 500mm max. from cover level and bottom iron 300mm above concrete base.
4. Pipes to have flexible joints (F.J.) at a maximum of 500mm. from concrete ring.
5. Covers shall be laid on a proprietary recycled plastic interlocking brick system. Where covers are used in verges and footway Class B engineering bricks may be used as an alternative, 1 No. course minimum depth.
6. Minimum soakaway diameter is 1200mm.



Growth, Highways & Infrastructure
Suffolk County Council
Endeavour House
8 Russell Road
Ipswich
Suffolk IP1 2BX

DRAWING TITLE
DRAINAGE AND SERVICE DUCTS
SOAK AWAY

REV.	DESCRIPTION	CHECKED	DATE

ORIGINATOR	INIT.	DATE	PROJECT TITLE	
RY	RY	08/2024	STANDARD CONSTRUCTION DETAILS	
CHECKER	SH	08/2024	SCALE	DATE
RY	RY	08/2024	N.T.S.	AUG. 2024
DESIGNER	TK	08/2024	DRAWING No.	
TK	TK	08/2024	DM-500-02	
REVIEWER				