



NOTES

Gully

1. The minimum depth from the top of the grate to the top of the gully outlet is to be 750 when the connecting pipe is under the carriageway. Depth of gully pot to be 900mm in primary and secondary roads and, 750 mm in tertiary and shared surface roads.
2. Gully may be cast insitu using a plastic gully as permanent formwork, or precast concrete.

Grating and Frame

3. To be D400 double triangular or hinged as required by the SCC.
4. Gully frame to be set 5–10mm below carriageway surface.
5. Precast concrete riser units are to be used. Reinstatement to be proprietary mastic asphalt or HRA as agreed with SCC.
6. Rodding eye to have stopped and chain installed.



Growth, Highways & Infrastructure
Suffolk County Council
Endeavour House
8 Russell Road
Ipswich
Suffolk IP1 2BX

DRAWING TITLE
DRAINAGE AND SERVICE DUCTS
PRECAST GULLY

REV.	DESCRIPTION	CHECKED	DATE

INIT.	DATE	PROJECT TITLE	
ORIGINATOR	RY 08/2024	STANDARD CONSTRUCTION DETAILS	
CHECKER	SH 08/2024	SCALE	DATE
DESIGNER	RY 08/2024	N.T.S.	AUG. 2024
REVIEWER	TK 08/2024	DRAWING No. DM-500-03	