



SECTION

NOTES

1. Dimensions H and W as specified by SCC. Side slopes to ditches either as existing or as specified by SCC.
2. The first pipe joint shall be flexible and located not more than 300mm from the back of the headwall.
3. Where the ditch outfalls into the pipe the invert of the pipe shall be level with the top of the apron.



Growth, Highways & Infrastructure
Suffolk County Council
Endeavour House
8 Russell Road
Ipswich
Suffolk IP1 2BX

DRAWING TITLE

DRAINAGE AND SERVICE DUCTS
BRICK HEADWALL

REV.	DESCRIPTION	CHECKED	DATE

INIT.	DATE	PROJECT TITLE	
ORIGINATOR	RY 08/2024	STANDARD CONSTRUCTION DETAILS	
CHECKER	SH 08/2024	SCALE	DATE
DESIGNER	RY 08/2024	N.T.S.	AUG. 2024
REVIEWER	TK 08/2024	DRAWING No. DM-500-14	