



NOTES

1. M20 lifting sockets to be filled in once placed with epoxy resin.
2. Guardrails may be required; to be agreed with SCC.
3. For pipes 450mm dia. and above, a hinge coupling grating is required.
4. Pipe diameter will determine the size of the headwall.



Growth, Highways & Infrastructure
Suffolk County Council
Endeavour House
8 Russell Road
Ipswich
Suffolk IP1 2BX

DRAWING TITLE

DRAINAGE AND SERVICE DUCTS
TYPICAL PRECAST HEADWALL

REV.	DESCRIPTION	CHECKED	DATE

ORIGINATOR	INIT.	DATE	PROJECT TITLE	
RY	RY	08/2024	STANDARD CONSTRUCTION DETAILS	
CHECKER	SH	08/2024	SCALE	DATE
RY	RY	08/2024	N..T.S.	AUG. 2024
DESIGNER	TK	08/2024	DRAWING No.	
TK	TK	08/2024	DM-500-21	
REVIEWER				