



NOTES

1. Wiring shall be kept in a neat and orderly manner by means of ties or similar and kept to one side of the control equipment/backboard.
2. Fused outlets, fuse to BS88 (or MCB as specified by client)



ESuffolk County Council
 Endeavour House
 8 Russell Road
 Ipswich
 Suffolk IP1 2BX

ELECTRICAL WORKS
 TYPICAL BASE COMPARTMENT WIRING
 SWITCH AND FUSED R.E.C SUPPLY
 TWO OUTGOING CIRCUITS

REV.	DESCRIPTION	CHECKED	DATE

ORIGINATOR	INIT.	DATE	PROJECT TITLE	
CG	CG	03/22	STANDARD CONSTRUCTION DETAIL	
CHECKER	AA	09/22	SCALE	DATE
DESIGNER	PW	09/22	N.T.S.	SEPT 2022
REVIEWER	RIB	04/22	DRAWING No. SCD 1400-6	